

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

This notice contains important information regarding your drinking water.
If the Spanish notice is not included, please contact the water system and ask for a copy.

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

MONITORING REQUIREMENTS NOT MET FOR CAZADERO WATER COMPANY (PUC)

Our water system failed to monitor as required for drinking water standards during the past year and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During recent triennial period ending in 2023, we failed to monitor for Total Trihalomethanes and Haloacetic Acids, and therefore, cannot be sure of the quality of our drinking water during that time.

What should I do?

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) we did not properly test for during the last year, how many samples we are required to take and how often, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required Sampling Frequency	Number of Samples Taken	When All Samples Should Have Been Taken	When Samples Were or Will Be Taken
Total Trihalomethanes (TTHM)	1 sample every 3 years	0	September 2023	August - September 2024
Haloacetic Acids (HAA5)	1 sample every 3 years	0	September 2023	August - September 2024

- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Cazadero Water Company (PUC) failed to monitor for Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5) in September 2023. Samples will be collected in August – September 2024 and continue triennially per the Disinfectants/Disinfection Byproducts Monitoring Plan approved by the California Department of Public Health on September 3, 2013.

For more information, please contact Russian River Utility at 707-887-7735 or PO Box 730, Forestville, CA 95436.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by Cazadero Water Company (PUC)

State Water System ID#: CA4900508

Population served: 250

Date distributed: August 23, 2024